

Confirmation

LEED v4.1

On 20 November 2020, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

MO-VS

supplied by

Index Técnicas Expansivas, S.L.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH 01350 testing standard (See test report no. 392-2019-00486603_H_EN_03).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

2 March 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.