

CERTIFICATE OF COMPLIANCE

Certificate Number 20181030-EX27926
Report Reference EX27926
Issue Date 2018-October-30

Issued to: TECNICAS EXPANSIVAS S L
Calle Segador 13
26006 Logrono, Spain

This is to certify that representative samples of Hangers, Pipe

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 203, "Pipe Hanger Equipment for Fire Protection Service."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

See addendum page 2



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181030-EX27926
Report Reference EX27926
Issue Date 2018-October-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model Designation	Hanger Type	Rod Size	Nominal Pipe Size	Comments
ABCH	Clevis Hanger	3/8 in.	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	—
ABCH	Clevis Hanger	24 mm	10, 12	—
ABCH	Clevis Hanger	1/2 in.	2-1/2, 3, 3-1/2	—
ABCH	Clevis Hanger	5/8 in.	4, 5	—
ABCH	Clevis Hanger	3/4 in.	6, 8	—



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

